

Chief Operator's Report for the Water Department

Presented: December 12, 2011

Accomplishments:

- 2013 first draft budgets complete
- Repaired broken decant manhole at the backwash plant
- Repair dechlor main piping leaving the chemical room
- Serviced both Trucks
- Fixed broken valve boxes at Field St Well
- took week of 14th and 21st off vacation (no deer)