

Chief Operator's Report for the Wastewater Department

Presented: November 14, 2011

Accomplishments:

- Replaced floats on Baffle in Lagoon.
- Started repairing aeration leaks in lagoon
- Cleaned and winterized the blower building.
- Worked with HW on Holden Ave Cleaning and tracing of storm water lines. Installed a new catch basin at the Carter residence.
- Pulled sewer pumps for repairs from Park, Styles, and Willow St.
- Checked all heaters for proper function at all pump stations.
- Proctor Gas checked and serviced all heaters at the WWTF
- Yearly maintenance and service complete on all Emergency generators
- Replaced sump pumps at Styles and Willow St Pump Stations.